



Course of
"Automatic Control Systems"
2023/24

PID controller: Ziegler and Nichols tuning methods

Prof. Francesco Montefusco

Department of Economics, Law, Cybersecurity, and Sports Sciences

Università degli Studi di Napoli Parthenope

francesco.montefusco@uniparthenope.it

Team code: **mfs9zfr**



Ziegler-Nichols tuning methods

- ✦ The **Ziegler–Nichols tuning method** is a heuristic method of tuning a PID controller.
- ✦ Controller tuning is the process of determining the controller parameters which produce the desired output.
- ✦ It allows the optimization of a closed loop performance and minimizes the error between the variable of the process and its set point.
- ✦ The Ziegler-Nichols methods are **trial and error** method often used when the mathematical model of the system is not available
- ✦ The Ziegler-Nichols methods can be used for both **closed** and **open loop systems**




Ziegler-Nichols closed loop method

- ✦ The Ziegler-Nichols closed loop method is a simple method of tuning PID controllers by means of a number of tests carried out on the control system in closed loop with the PID controller
- ✦ It can be used only with regularly stable systems: closed loop systems moving toward the instability when the proportional gain increases
- ✦ Let us define **ultimate gain \bar{K}_P** the proportional gain which gives stable and consistent oscillations for closed loop systems
- ✦ **\bar{K}_P is found experimentally** by starting from a small value of K_P and adjusting upwards until consistent oscillations are obtained. The integral and derivative actions are set to zero.
- ✦ Another important value associated with the ultimate gain **\bar{K}_P** is **the ultimate period \bar{T}** . The ultimate period is the time required to complete one full oscillation while the system is at steady state




Ziegler-Nichols closed loop method



Source: ControlsWiki

Ziegler-Nichols closed loop method


- The parameters, \bar{K}_P and \bar{T} are used to find the loop-tuning constants of the controllers (P, PI, or PID)



	K_P	T_I	T_D
P	$0.5\bar{K}_P$		
PI	$0.45\bar{K}_P$	$0.8\bar{T}$	
PID	$0.6\bar{K}_P$	$0.5\bar{T}$	$0.125\bar{T}$

- ✦ Let us design a
 - ✦ Proportional (P) controller
 - ✦ Proportional-Integral (PI) controller
 - ✦ a Proportional-Integral-Derivative (PID) controller

for the closed loop system



- ✦ The mechanical systems is a mass-friction-damper system


$$m\ddot{y}(t) + b\dot{y}(t) + ky(t) = u(t)$$

with $m = 1$ Kg, $k = 25$ N/m, $b = 20$ Ns/m .

- ✦ The actuator is modelled with a first order system in the form


$$\dot{f}(t) + 50f(t) = 50u(t)$$

- ✦ The P, PI and PID controllers have been tuned with the Ziegler-Nichols closed loop method






Ziegler-Nichols closed loop method: example Performance




P-controller

- No-null steady state error
- Overshoot $s \cong 50\%$



PI-controller

- Null steady state error
- Overshoot $s \cong 80\%$ with more pronounced oscillating response




PID-controller

- Null steady state error
- Overshoot $s \cong 30\%$ with fast response




Ziegler-Nichols closed loop method: example

Control signal




P-controller

- Control input peak = 60
- Slow oscillations



PI-controller

- Control input peak = 60
- Fast oscillations



PID-controller

- Control input peak = 1200
- NO oscillations

**TUNING
REFINEMENT
IS NECESSARY**




Ziegler-Nichols open loop method

- ✧ The Ziegler-Nichols open-loop method is also referred to as a process reaction method, because it tests the open-loop reaction of the process to a change in the control variable output.
- ✧ The Ziegler-Nichols open loop method can be applied on processes whose step response doesn't oscillate.
- ✧ To use the Ziegler-Nichols open-loop tuning method, you must perform the following steps:
 - ✧ Evaluate the open loop unitary step response of the process
 - ✧ From the process reaction curve, determine
 - the transportation lag or dead time T ,
 - the equivalent time constant τ
 - the steady state value G of the step response



Ziegler-Nichols open loop method



Tangent to the step response at the point of inflection



Ziegler-Nichols open loop method

Dead time T : time interval defined by the intersection of the tangent to the step response at the point of inflection and the time-axis

Equivalent time constant τ : Time interval from T to the intersection of the tangent to the step response at the point of inflection and the line indicating the steady-state value G



Ziegler-Nichols open loop method

- ✦ The parameters, T , τ and G are used to find the loop-tuning constants of the controllers (P, PI, or PID)

	K_P	T_I	T_D
P	$\frac{\tau}{TG}$		
PI	$\frac{0.9\tau}{TG}$	$3T$	
PID	$\frac{1.2\tau}{TG}$	$2T$	$0.5T$